



Italia

COMPLIANCE

with IEC EN 61508 and IEC EN 61511

Certificate No.: C-IS-722169914 Rev.1

CERTIFICATE OWNER: **ORION S.p.A.**
VIA CABOTO, 8
I-34148 – TRIESTE (Italy)

WE HEREWITH CONFIRM THAT

THE ANALYSIS DEVELOPED BY ORION; REPORTED IN THE REPORT:

“ORION, Safety Analysis Report for Gate Valves – N° 010/2015 Rev.01 dated June, 25th 2018”

MEETS THE SIL REQUIREMENTS DETAILED IN THE ANNEXED TABLE FOR THE SAFETY FUNCTIONS:

“Switching on demand (open to closed / closed to open) and sealing in closed position in low demand mode of operation”

Examination result:

The above described report was found to meet the standard defined requirements of the safety levels detailed in the following tables (T-IS-722169914 Rev.1) according to IEC EN 61508 and IEC EN 61511, under fulfillment of the conditions listed in the Report R-IS-722169914 Rev.1 dated July, 23rd 2018 in its currently valid version, on which this Certificate is based

Examination parameters:

Compliance of the operational approach adopted and followed in the aforementioned report by ORION: *“ORION, Safety Analysis Report for Gate Valves – N° 010/2015 Rev.01 dated June, 25th 2018”*.

Official Report No.:

R-IS-722169914 Rev.1

Expiry Date

July, 22nd 2021

**IT IS TO BE INTENDED THAT THE ABOVE OFFICIAL REPORT AND ITS ANNEXES ARE AN INTEGRAL PART OF THIS DOCUMENT
THE PRESENT DOCUMENT SUBSTITUTES AND REPEALS THE DOCUMENT C-IS-260811-01**

Reference Standards

IEC EN 61508:2010 Part 2, 4, 6, 7
IEC EN 61511:2016 Part 1, 2, 3

Sesto San Giovanni, May, 07th 2020
TÜV ITALIA Srl



TÜV ITALIA Srl
Industry Service Division
Technical manager

Paolo Marcone



Italia

SUMMARY TABLE

T-IS-722169914 Rev.1

<i>E/EE/EP safety-related system (final element)</i>	Gate Valves produced by ORION			
<i>System type</i>	Type A			
<i>Systematic Capability</i>	SC3			
<i>Class⁽¹⁾</i>	Class 1 / Temperature range HT (from -29 to +400°C) Service NON-NACE		Class 2 / Temperature range HT (from -29 to +400°C) Service NACE	
<i>Safety Function Definition</i>	Switching on demand (open to closed / closed to open) and sealing in closed position in low demand mode of operation			
<i>Max SIL⁽²⁾</i>	SIL 2 with HFT=0 (single valve configuration)	SIL3 with HFT=1 (redundant configuration)	SIL 2 with HFT=0 (single valve configuration)	SIL3 with HFT=1 (redundant configuration)
λ_{TOT}	1,17E-07		4,14E-07	
λ_{SD}	0,00E+00		0,00E+00	
λ_{SU}	8,13E-08		2,89E-07	
λ_{DD}	0,00E+00		0,00E+00	
λ_{DU}	3,52E-08		1,25E-07	
$\lambda_{DU,PST}^{(3)}$	2,71E-08		9,63E-08	
$\lambda_{DU,FPT}^{(4)}$	8,12E-09		2,88E-08	
<i>β and β_D factor</i>	10%		10%	
<i>MTTR</i>	24 h		24 h	
<i>Hardware Safety Integrity</i>	Route 2 _H		Route 2 _H	
<i>Systematic Safety Integrity</i>	Route 2 _s		Route 2 _s	
Remarks				
(1) Category identified according to specific environment and application, in particular for fluid type and temperature range. Refer to product safety manual for detailed information on the categories.				
(2) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.				
(3) Portion of the overall failure rate related to dangerous failure modes that can be detected by means of Partial Stroke Testing (DU,PST).				
(4) Portion of the overall failure rate related to dangerous failure modes that can be detected by means of Full Proof Test (DU,FPT).				

SIL classification according to Standards IEC EN 61508:2010 (Chapters: 2, 4, 6, 7) and IEC EN 61511:2016 (Chapters: 1, 2, 3) for GATE VALVES produced by ORION S.p.A.

T-IS-722169914 Rev.1

NOTE: The present table is integral part of the Document: C-IS-722169914 Rev.1

Date: May, 07th 2020



Italia

SUMMARY TABLE

T-IS-722169914 Rev.1

<i>E/EE/EP safety-related system (final element)</i>	Gate Valves produced by ORION			
<i>System type</i>	Type A			
<i>Systematic Capability</i>	SC3			
<i>Class⁽¹⁾</i>	Class 3 / Temperature range LT (from -196°C to 200°C) Service NACE		Class 4 / Temperature range LT (from -196°C to 200°C) Service NON-NACE	
<i>Safety Function Definition</i>	Switching on demand (open to closed / closed to open) and sealing in closed position in low demand mode of operation			
<i>Max SIL⁽²⁾</i>	SIL 2 with HFT=0 (single valve configuration)	SIL3 with HFT=1 (redundant configuration)	SIL 2 with HFT=0 (single valve configuration)	SIL3 with HFT=1 (redundant configuration)
λ_{TOT}	9,28E-08		9,99E-10	
λ_{SD}	0,00E+00		0,00E+00	
λ_{SU}	6,47E-08		6,97E-10	
λ_{DD}	0,00E+00		0,00E+00	
λ_{DU}	2,81E-08		3,02E-10	
$\lambda_{DU,PST}^{(3)}$	2,16E-08		2,33E-10	
$\lambda_{DU,FPT}^{(4)}$	6,47E-09		6,97E-11	
<i>β and β_D factor</i>	10%		10%	
<i>MTTR</i>	24 h		24 h	
<i>Hardware Safety Integrity</i>	Route 2 _H		Route 2 _H	
<i>Systematic Safety Integrity</i>	Route 2 _s		Route 2 _s	
Remarks				
(1) Category identified according to specific environment and application, in particular for fluid type and temperature range. Refer to product safety manual for detailed information on the categories.				
(2) The Safety Integrity Level (SIL) of the entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD _{AVG} considering the redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with the minimum hardware fault tolerance (HFT) requirements.				
(3) Portion of the overall failure rate related to dangerous failure modes that can be detected by means of Partial Stroke Testing (DU,PST).				
(4) Portion of the overall failure rate related to dangerous failure modes that can be detected by means of Full Proof Test (DU,FPT).				

SIL classification according to Standards IEC EN 61508:2010 (Chapters: 2, 4, 6, 7) and IEC EN 61511:2016 (Chapters: 1, 2, 3) for GATE VALVES produced by ORION S.p.A.

T-IS-722169914 Rev.1

NOTE: The present table is integral part of the Document: C-IS-722169914 Rev.1

Date: May, 07th 2020